

City of Montpelier: Priority for ADA Transition Plan

Priorities:

- Priority 1: Program Access*
- Priority 2: Safety or Navigational Issue
- Priority 3: Additional Access*
- Priority 4: Enhanced Usability

*Note:

Some toilet rooms issues compromise Program Access. Some toilet rooms with less central issues (e.g., partially accessible toilet rooms), fall under Additional Access.

**IHCD Cost Estimation Notes:

- Cost of design is not included.
- Does not include costs when note indicates future work.
- Labor cannot be estimated for all remedies.
- There is no cost noted when it's presumed to be a maintenance issue.
- Cost based on a national average. Cost is not based on prevailing wage.
- There is no cost noted when it's presumed to be a maintenance issue. *Estimates are intended as a guide to budgeting access modifications and are not intended to be absolutely comprehensive or definitive.*



| Information Provided by Institute for Human Centered Design | | | | | | | | | | | Project Management for the City of Montpelier | | | |
|-------------------------------------------------------------|---------------|-------------------------------------|-------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|------|-----|---------------|------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------------------|--------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 1 | Hubbard Park | A. Exterior Access Route | A. Not provided from all site arrival points | Observation Tower | Ext. | | Priority 1 | Program Access | Ensure an accessible route is provided from all points of arrival (parking). | 1 | \$390 | | | |
| 2 | Hubbard Park | A. Exterior Access Route | A. Not provided from all site arrival points N. Running slope > 1:20 (5.00%) | Old Shelter Pavilion Soccer and Softball Field | Ext. | | Priority 1 | Program Access | Accessible route is technically infeasible. Consider providing a soccer field at an accessible location. | 1 | \$0 | | | |
| 3 | Hubbard Park | A. Exterior Access Route | F. Surface openings > 1/2" | Path to New Shelter Pavilion | Ext. | | Priority 1 | Program Access | Replace or reposition so that openings are 1/2" max. | 1 | \$0 | | | |
| 4 | Hubbard Park | A. Exterior Access Route | J. Level changes > 1/4" | New Shelter Pavilion | Ext. | | Priority 1 | Program Access | Alter change in level to be 1/4" high max. | 1 | \$103 | | | |
| 5 | Hubbard Park | A. Exterior Access Route | K. Surface not stable, firm, and slip-resistant O. Accessible route not provided | Fitness Station 15 | Ext. | | Priority 1 | Program Access | Accessible route to all workout stations is technically infeasible. Recommend providing representative set of workout stations in an alternate accessible location. Note: Cost dependent upon final design. | 1 | \$0 | | | |
| 6 | Hubbard Park | A. Exterior Access Route | O. Accessible route not provided | New Shelter Pavilion Trailhead Outhouse | Ext. | | Priority 1 | Program Access | Ensure an accessible route is provided to the outhouse. Reduce running slope to 10% max. for ten feet and 8.33% max. for 30 feet. | 1 | \$300 | | | |
| 7 | Hubbard Park | E. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces | Dog Run | Ext. | | Priority 1 | Program Access | Provide a van accessible space with marked access aisle and sign that includes the International Symbol of Accessibility and the words "Van Accessible" positioned 60" min. above the ground. Note: See provided drawing of one design option for designating accessible spaces in unpaved parking lots. | 1 | \$925 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | | Project Management for the City of Montpelier | | |
|-------------------------------------------------------------|---------------|-------------------------------------|-------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------|------|-----|---------------|------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------|-----------------------------------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 8 | Hubbard Park | E. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces | New Shelter Pavilion Parking | Ext. | | Priority 1 | Program Access | Provide a van accessible space with marked access aisle and sign that includes the International Symbol of Accessibility and the words "Van Accessible" positioned 60" min. above the ground. Note: See provided drawing of one design option for designating accessible spaces in unpaved parking lots. | 1 | \$925 | | | |
| 9 | Hubbard Park | E. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces | Observation Tower Parking | Ext. | | Priority 1 | Program Access | Provide a van accessible space with marked access aisle and sign that includes the International Symbol of Accessibility and the words "Van Accessible" positioned 60" min. above the ground. Note: See provided drawing of one design option for designating accessible spaces in unpaved parking lots. | 1 | \$925 | | | |
| 10 | Hubbard Park | E. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces | Old Shelter Pavilion | Ext. | | Priority 1 | Program Access | Provide a van accessible space with marked access aisle and sign that includes the International Symbol of Accessibility and the words "Van Accessible" positioned 60" min. above the ground. Note: See provided drawing of one design option for designating accessible spaces in unpaved parking lots. | 1 | \$925 | | | |
| 11 | Hubbard Park | E. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces | Parking Between Winter Street and Old Pavilion Shelter | Ext. | | Priority 1 | Program Access | Provide a van accessible space with marked access aisle and sign that includes the International Symbol of Accessibility and the words "Van Accessible" positioned 60" min. above the ground. Note: See provided drawing of one design option for designating accessible spaces in unpaved parking lots. | 1 | \$925 | | | |
| 12 | Hubbard Park | E. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces | Seven Fireplaces Entrance Parking | Ext. | | Priority 1 | Program Access | Provide a van accessible space with marked access aisle and sign that includes the International Symbol of Accessibility and the words "Van Accessible" positioned 60" min. above the ground. Note: See provided drawing of one design option for designating accessible spaces in unpaved parking lots. | 1 | \$925 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | | Project Management for the City of Montpelier | | |
|-------------------------------------------------------------|---------------|-------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------|------|-----|---------------|------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------|-----------------------------------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 13 | Hubbard Park | E. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces | Seven Fireplaces Parking | Ext. | | Priority 1 | Program Access | Provide a van accessible space with marked access aisle and sign that includes the International Symbol of Accessibility and the words "Van Accessible" positioned 60" min. above the ground. Note: See provided drawing of one design option for designating accessible spaces in unpaved parking lots. | 1 | \$925 | | | |
| 14 | Hubbard Park | E. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces | Winter Street Parking | Ext. | | Priority 1 | Program Access | Provide a van accessible space with marked access aisle and sign that includes the International Symbol of Accessibility and the words "Van Accessible" positioned 60" min. above the ground. Note: See provided drawing of one design option for designating accessible spaces in unpaved parking lots. | 1 | \$925 | | | |
| 15 | Hubbard Park | Program Access | | Observation Tower | Ext. | | Priority 1 | Program Access | Program access - recommend creating display on an accessible route with photos of the interior of the tower and photos of views from the tower. Also recommend placing the images and descriptions on the park web site in an accessible format. | 1 | \$0 | | | |
| 16 | Hubbard Park | E. Signage | A. Not provided | Old Shelter Pavilion | Ext. | | Priority 2 | Navigational Issue | Provide directional sign indicating accessible route to the the backside accessible pavilion entrance. | 1 | \$116 | | | |
| 17 | Hubbard Park | G. Operable Parts | D. Side reach > 54" | Dog Run | Ext. | | Priority 3 | Additional Access | Relocate so that dispenser opening is between 15" - 48" above the ground. | 1 | \$128 | | | |
| 18 | Hubbard Park | J. Picnic Tables | A. Number of seating spaces at picnic tables B. Number of accessible seating spaces H. Picnic table not on an accessible route | Near Old Shelter Pavilion Soccer and Softball Field | Ext. | | Priority 1 | Program Access | Accessible route to pavilion beyond soccer field is technically infeasible. Direct visitors to other accessible pavilions with accessible picnic tables in park. | 1 | \$0 | | | |
| 19 | Hubbard Park | J. Picnic Tables | B. Number of accessible seating spaces | Observation Tower | Ext. | | Priority 1 | Program Access | Provide at least one accessible picnic table with top between 28"- 34" above the ground and 27" clear height underneath, 30 inches wide min., and 19 inches min. deep. | 1 | \$700 | | | |
| 20 | Hubbard Park | J. Picnic Tables | H. Picnic table not on an accessible route B. Number of accessible seating spaces | Seven Fireplaces | Ext. | | Priority 1 | Program Access | Locate picnic table on an accessible route. Provide at least one accessible picnic table with top between 28"- 34" above the ground and 27" clear height underneath, 30 inches wide min., and 19 inches min. deep. | 1 | \$850 | | | |
| 21 | Hubbard Park | K. Grills | A. Not on a accessible route | Near New Shelter Pavilion | Ext. | | Priority 1 | Program Access | Ensure grills are located on an accessible route. | 1 | \$30 | | | |
| 22 | Hubbard Park | K. Grills | A. Not on a accessible route | Near Old Shelter Pavilion | Ext. | | Priority 1 | Program Access | Ensure grill/fireplace is located on an accessible route. | 1 | \$150 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | | Project Management for the City of Montpelier | | |
|-------------------------------------------------------------|---------------|-----------------------|--------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------|------|-----|---------------|------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------|-----------------------------------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 23 | Hubbard Park | K. Grills | A. Not on a accessible route | Seven Fireplaces | Ext. | | Priority 1 | Program Access | Ensure grill/fireplace is located on an accessible route. | 1 | \$300 | | | |
| 24 | Hubbard Park | K. Grills | A. Not on a accessible route | Seven Fireplaces | Ext. | | Priority 1 | Program Access | Ensure grills are located on an accessible route. | 1 | \$300 | | | |
| 25 | Hubbard Park | L. Benches | A. No accessible route to 20% of benches | Observation Tower | Ext. | | Priority 1 | Program Access | Provide a park bench located on an accessible route. | 1 | \$650 | | | |
| 26 | Hubbard Park | A. Drinking Fountains | A. Fountain not on accessible route E. Spout < 38" or > 43" (standing users) J. No drinking fountain provided for seated users | Water Fountain | Ext. | | Priority 1 | Program Access | Provide an accessible Hi-Lo drinking fountain. | 1 | \$2,018 | | | |
| 27 | Hubbard Park | A. Drinking Fountains | H. No drinking fountain provided for standing users | Old Shelter Pavilion | Ext. | | Priority 1 | Program Access | Provide an accessible Hi-Lo drinking fountain. | 1 | \$2,018 | | | |
| 28 | Hubbard Park | Signage | | Near Fitness Station 15 | Ext. | | Priority 4 | Enhanced Usability | Consider identifying trail name and/or destination on sign. | 1 | \$0 | | | |
| 29 | Hubbard Park | Toilet Rooms | A. Not on an accessible route B. Turning space not provided C. Accessible plumbing fixtures or stalls not provided | New Shelter Pavilion Trailhead Outhouse | Ext. | | Priority 4 | Enhanced Usability | Recommend providing an accessible toilet room. Ensure clear floor space of 56" min. x 60" min. at the toilet. Provide a side grab bar 42" long min., located 12" max. from the rear wall, and a rear grab bar 36" long min., extending 24" min. from the centerline of the toilet on the transfer side. Ensure door is at least 32" wide with a ½" max. threshold. Note: Cost dependent upon final design. | 1 | \$0 | | | |
| 30 | Hubbard Park | Toilet Rooms | A. Not on an accessible route B. Turning space not provided C. Accessible plumbing fixtures or stalls not provided | Near Observation Tower | Ext. | | Priority 4 | Enhanced Usability | Recommend providing an accessible toilet room. Ensure clear floor space of 56" min. x 60" min. at the toilet. Provide a side grab bar 42" long min., located 12" max. from the rear wall, and a rear grab bar 36" long min., extending 24" min. from the centerline of the toilet on the transfer side. Ensure door is at least 32" wide with a ½" max. threshold. Note: Cost dependent upon final design. | 1 | \$0 | | | |
| 31 | Hubbard Park | Toilet Rooms | A. Not on an accessible route B. Turning space not provided C. Accessible plumbing fixtures or stalls not provided | Old Shelter Pavilion | Ext. | | Priority 4 | Enhanced Usability | Recommend providing an accessible toilet room. Ensure clear floor space of 56" min. x 60" min. at the toilet. Provide a side grab bar 42" long min., located 12" max. from the rear wall, and a rear grab bar 36" long min., extending 24" min. from the centerline of the toilet on the transfer side. Ensure door is at least 32" wide with a ½" max. threshold. Note: Cost dependent upon final design. | 1 | \$0 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | | Project Management for the City of Montpelier | | |
|-------------------------------------------------------------|----------------------------------------------------|--------------------------|--------------------------------------------------------------------------------------------------------------------------|---------------------------------|------|-----|---------------|------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------|-----------------------------------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 32 | Hubbard Park | Toilet Rooms | A. Not on an accessible route B. Turning space not provided C. Accessible plumbing fixtures or stalls not provided | Old Shelter Pavilion | Ext. | | Priority 4 | Enhanced Usability | Recommend providing an accessible toilet room. Ensure clear floor space of 56" min. x 60" min. at the toilet. Provide a side grab bar 42" long min., located 12" max. from the rear wall, and a rear grab bar 36" long min., extending 24" min. from the centerline of the toilet on the transfer side. Ensure door is at least 32" wide with a ½" max. threshold. Note: Cost dependent upon final design. | 1 | \$0 | | | |
| 33 | Hubbard Park | Toilet Rooms | A. Not on an accessible route B. Turning space not provided C. Accessible plumbing fixtures or stalls not provided | Seven Fireplaces | Ext. | | Priority 4 | Enhanced Usability | Recommend providing an accessible toilet room. Ensure clear floor space of 56" min. x 60" min. at the toilet. Provide a side grab bar 42" long min., located 12" max. from the rear wall, and a rear grab bar 36" long min., extending 24" min. from the centerline of the toilet on the transfer side. Ensure door is at least 32" wide with a ½" max. threshold. Note: Cost dependent upon final design. | 1 | \$0 | | | |
| 34 | Hubbard Park | | | New Shelter Pavilion Trailhead | Ext. | | Priority 4 | Enhanced Usability | Recommend providing wood railings with railing extensions on both sides. | 1 | \$0 | | | |
| 35 | Hubbard Park | | | Observation Tower | 1 | | Priority 4 | Enhanced Usability | Recommend providing wood railings with railing extensions on both sides. | 2 | \$0 | | | |
| 36 | Hubbard Park | | | Old Shelter Pavilion | Ext. | | Priority 4 | Enhanced Usability | Recommend providing wood railings with railing extensions on both sides. | 1 | \$0 | | | |
| 37 | Hubbard Park | | | Trail (Near Fitness Station 15) | Ext. | | Priority 4 | Enhanced Usability | Recommend providing wood railings with railing extensions on both sides. | 2 | \$0 | | | |
| 38 | Hubbard Park | | Stairs have open risers. | Observation Tower | Ext. | | Priority 4 | Enhanced Usability | Recommend closing open risers. | 1 | \$0 | | | |
| 1 | Montpelier Elm Street Recreation and Swimming Pool | A. Exterior Access Route | G. Cross slope > 1:50 (2.00%) | By Pool House | Ext. | | Priority 1 | Program Access | Reduce cross slope to be no steeper than 1:50 (2.00%). (Cost estimate for adding 60' of concrete to correct pathway slope.) | 1 | \$900 | | | |
| 2 | Montpelier Elm Street Recreation and Swimming Pool | A. Exterior Access Route | H. Running slope > 1:20 (5%) J. Level changes > 1/4" | Playground | Ext. | | Priority 1 | Program Access | Reduce running slope to be no steeper than 1:20 (5%). Alter change in level to be 1/4" high max. (Cost estimate for adding 30' of concrete to correct pathway slope and level changes.) | 1 | \$450 | | | |
| 3 | Montpelier Elm Street Recreation and Swimming Pool | A. Exterior Access Route | J. Level changes > 1/4" | Small Baseball Field - Dugout | Ext. | | Priority 1 | Program Access | Alter change in level to be 1/4" high max. | 1 | \$103 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | Project Management for the City of Montpelier | | | |
|-------------------------------------------------------------|----------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|--------|-----|---------------|------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------------------|--------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 4 | Montpelier Elm Street Recreation and Swimming Pool | C. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces | Montpelier Recreation Field Parking | Ext. | | Priority 1 | Program Access | Provide three (3) accessible spaces, including one (1) van accessible space. Ensure that two (2) accessible spaces are at least 96" wide with 60" min. access aisle and the van accessible space is at least 132" wide with 60" min. access aisle. Provide three (3) ISA signs located 60" min. above the ground. Add the designation "Van Accessible" to the sign at the van accessible space. | 3 | \$2,775 | | | |
| 5 | Montpelier Elm Street Recreation and Swimming Pool | C. Off-Street Parking Lot or Garage | A. Total # of parking B. Total # of designated accessible parking spaces C. Total # of designated van accessible spaces N. Sign not provided | Swimming Pool Parking Lot | Ext. | | Priority 1 | Program Access | Provide two signs with the International Symbol of Accessibility with the bottom of the signs 60" min. above the ground. | 1 | \$500 | | | |
| 6 | Montpelier Elm Street Recreation and Swimming Pool | C. Off-Street Parking Lot or Garage | G. Access aisle not provided O. Sign does not have the designation "Van Accessible" | Swimming Pool Parking Lot | Ext. | | Priority 1 | Program Access | Provide a marked access aisle that is at least 60" wide (assuming the van space remains 132" mn. wide.) Add the designation "Van Accessible" to the sign and ensure the bottom of the sign is at least 60" above the ground. | 1 | \$400 | | | |
| 7 | Montpelier Elm Street Recreation and Swimming Pool | A. Means of Egress | B. Tactile exit sign not provided | Swimming Pool - Bath House | 1 | | Priority 2 | Safety | Ensure tactile exit signs with raised characters and braille are provided at exit doors leading to enclosed stairways. Mount signs between 48"- 60" above finish floor located on the latch side of the door. | 3 | \$348 | | | |
| 8 | Montpelier Elm Street Recreation and Swimming Pool | B. Interior Access Route | E. Level changes > 1/4" | Swimming Pool - Women's Toilet Room | 1 | | Priority 3 | Additional Access | Alter change in level to be 1/4" high max. | 1 | \$103 | | | |
| 9 | Montpelier Elm Street Recreation and Swimming Pool | C. Doors, Doorways, & Gates | L. Hardware not operable with a closed fist | Babe Ruth Field Press Box | Ext. | | Priority 3 | Additional Access | Provide hardware that can be operable with one hand and not require tight grasping, pinching, or twisting of the wrist. | 1 | \$242 | | | |
| 10 | Montpelier Elm Street Recreation and Swimming Pool | D. Ramps | B. Running slope >1:12 (8.33%) | Route to Pool | Ext. | | Priority 3 | Additional Access | Reduce running slope to be no steeper than 1:20 (5.00%). (Cost estimate adding a 60' switch back asphalt path to reduce slope to 5.00% max.) | 1 | \$780 | | | |
| 11 | Montpelier Elm Street Recreation and Swimming Pool | D. Ramps | B. Running slope >1:12 (8.33%) E. Handrails not provided at both sides if rise is > 6" G. Handrails have non-compliant cross section | Behind Bleachers | 1=Ext. | | Priority 3 | Additional Access | Reducing running slope is technically infeasible. | 1 | \$0 | | | |
| 12 | Montpelier Elm Street Recreation and Swimming Pool | H. Signage | B. Raised characters not provided D. Braille not provided | Swimming Pool - Women's and Men's Toilet Rooms | 1 | | Priority 2 | Navigational Issue | Provide text with raised characters duplicated in braille at women's and men's multi-user toilet rooms. | 2 | \$232 | | | |
| 13 | Montpelier Elm Street Recreation and Swimming Pool | J. Service Counter | B. Counter > 36" high | Baseball Concession Stand | Ext. | | Priority 3 | Additional Access | Provide a counter that is 36" max. above the ground. | 1 | \$440 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | | Project Management for the City of Montpelier | | |
|-------------------------------------------------------------|----------------------------------------------------|--------------------|--------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|------|-----|---------------|------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------|-----------------------------------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 14 | Montpelier Elm Street Recreation and Swimming Pool | J. Service Counter | B. Counter > 36" high | Concession Stand Near Little League Baseball Field | Ext. | | Priority 3 | Additional Access | Provide a counter that is 36" max. above the ground or finish floor. | 1 | \$440 | | | |
| 15 | Montpelier Elm Street Recreation and Swimming Pool | J. Service Counter | B. Counter > 36" high | Snack Bar | Ext. | | Priority 3 | Additional Access | Provide a counter that is 36" max. above the ground. | 1 | \$440 | | | |
| 16 | Montpelier Elm Street Recreation and Swimming Pool | J. Service Counter | B. Counter > 36" high | Snack Bar | Ext. | | Priority 3 | Additional Access | Provide a counter that is 36" max. above the ground. | 1 | \$440 | | | |
| 17 | Montpelier Elm Street Recreation and Swimming Pool | J. Service Counter | B. Counter > 36" high | Souvenir Gift Shop | Ext. | | Priority 3 | Additional Access | Provide a counter that is 36" max. above the ground or finish floor. | 1 | \$440 | | | |
| 18 | Montpelier Elm Street Recreation and Swimming Pool | O. Locker Room | A. Total # of locker B. Total # of accessible locker H. Non-compliant hardware | Swimming Pool Lockers | 1 | | Priority 3 | Additional Access | Provide hardware that can be operable with one hand and not require tight grasping, pinching, or twisting of the wrist at 5% min. (at least 2 lockers in this case). | 2 | \$680 | | | |
| 19 | Montpelier Elm Street Recreation and Swimming Pool | O. Locker Room | M. Back support not provided at bench | Swimming Pool - Women's Changing Room | 1 | | Priority 3 | Additional Access | Remove rear grab bar to provide back support that is 42" minimum in length and extends from a point 2" maximum above the seat to a point 18" minimum above the bench, with room on the side to transfer. (Cost for a piece of plywood on wall to provide uniform back support.) | 1 | \$100 | | | |
| 20 | Montpelier Elm Street Recreation and Swimming Pool | O. Locker Room | M. Back support not provided at bench | Swimming Pool Men's Changing Room | 1 | | Priority 3 | Additional Access | Remove rear grab bar and provide back support that is 42 inches minimum in length and extends from a point 2 inches maximum above the seat to a point 18 inches minimum above the bench, with room on the side to transfer. (Cost for a piece of plywood on wall to provide uniform back support.) | 1 | \$100 | | | |
| 21 | Montpelier Elm Street Recreation and Swimming Pool | S. Picnic Tables | B. Number of accessible seating spaces C. At least 5% accessible spaces not provided | Picnic Area Near Fields | Ext. | | Priority 1 | Program Access | Ensure that at least one picnic table is accessible with adequate toe and knee clearance. | 1 | \$700 | | | |
| 22 | Montpelier Elm Street Recreation and Swimming Pool | S. Picnic Tables | B. Number of accessible seating spaces C. At least 5% accessible spaces not provided G. Toe or knee clearance at tables not provided | The Garden | Ext. | | Priority 1 | Program Access | Ensure that at least one picnic table is accessible with adequate knee and toe clearance. | 1 | \$700 | | | |
| 23 | Montpelier Elm Street Recreation and Swimming Pool | T. Benches | B. 20% of benches have clear space < 36" x 48" | Playground Near Swimming Pool | Ext. | | Priority 1 | Program Access | Ensure that the bench has a clear floor space of 36" wide min. by 48" deep min. (Cost for a 3' by 3' asphalt patch alongside bench.) | 1 | \$18 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | | Project Management for the City of Montpelier | | |
|-------------------------------------------------------------|----------------------------------------------------|-----------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-----|-----|---------------|------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------|-----------------------------------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 24 | Montpelier Elm Street Recreation and Swimming Pool | A. Overall Access | B. Turning space not provided | Men's Toilet Room - Babe Ruth | 1 | | Priority 1 | Program Access | Remove interior partition and obstacles as needed to provide turning space. Alternatively redo restroom to provide an accessible stall. (Cost to remodel multi-user toilet room to provide an accessible stall.) | 1 | \$4,755 | | | |
| 25 | Montpelier Elm Street Recreation and Swimming Pool | A. Overall Access | B. Turning space not provided | Women's Toilet Room - Babe Ruth | 1 | | Priority 1 | Program Access | Remove interior partition and obstacles as needed to provide turning space. Alternatively redo restroom to provide an accessible stall. (Cost to remodel multi-user toilet room to provide an accessible stall.) | 1 | \$4,755 | | | |
| 26 | Montpelier Elm Street Recreation and Swimming Pool | A. Overall Access | H. Audible and visible alarms not provided | Men's and Women's Toilet Room - Babe Ruth | 1 | | Priority 1 | Program Access | When fire system is updated, ensure that a visible and audible fire alarm is installed. | 2 | \$692 | | | |
| 27 | Montpelier Elm Street Recreation and Swimming Pool | A. Overall Access | H. Audible and visible alarms not provided | Swimming Pool - Women's Toilet Room | 1 | | Priority 1 | Program Access | When fire system is updated, ensure that a visible and audible fire alarm is installed. | 1 | \$346 | | | |
| 28 | Montpelier Elm Street Recreation and Swimming Pool | A. Overall Access | H. Audible and visible alarms not provided | Swimming Pool Men's Toilet Room | 1 | | Priority 1 | Program Access | When fire system is updated, ensure that a visible and audible fire alarm is installed. | 1 | \$346 | | | |
| 29 | Montpelier Elm Street Recreation and Swimming Pool | B. Lavatory | C. Lavatory rim or counter > 34" high F. Mirror above lavatory w/reflective surface > 40" | Women's Toilet Room Babe Ruth | 1 | | Priority 1 | Program Access | Provide at least one lavatory with the rim no higher than 34". Lower mirror so that the bottom surface is at 40" max. above finish floor. | 1 | \$1,675 | | | |
| 29 | Montpelier Elm Street Recreation and Swimming Pool | B. Lavatory | E. Plumbing underneath is exposed | Women's Toilet Room Babe Ruth | 1 | | Priority 2 | Safety | Insulate or otherwise configure pipes to prevent contact, for at least one lavatory. | 1 | \$46 | | | |
| 30 | Montpelier Elm Street Recreation and Swimming Pool | B. Lavatory | D. Faucet is not operable with a closed fist | Men's Toilet Room Babe Ruth | 1 | | Priority 1 | Program Access | Provide a faucet that can be operable with one hand and not require tight grasping, pinching, or twisting of the wrist for at least one lavatory. | 1 | \$493 | | | |
| 30 | Montpelier Elm Street Recreation and Swimming Pool | B. Lavatory | F. Mirror above lavatory w/reflective surface > 40" | Men's Toilet Room Babe Ruth | 1 | | Priority 3 | Additional Access | Lower mirror so that the bottom surface is at 40" max. above finish floor. | 1 | \$128 | | | |
| 31 | Montpelier Elm Street Recreation and Swimming Pool | B. Lavatory | E. Plumbing underneath is exposed | Swimming Pool - Women's Toilet Room | 1 | | Priority 2 | Safety | Insulate or otherwise configure pipes to prevent contact, for at least one lavatory. | 1 | \$46 | | | |
| 32 | Montpelier Elm Street Recreation and Swimming Pool | B. Lavatory | E. Plumbing underneath is exposed | Swimming Pool Men's Toilet Room | 1 | | Priority 2 | Safety | Insulate or otherwise configure pipes to prevent contact, for at least one lavatory. | 1 | \$46 | | | |
| 33 | Montpelier Elm Street Recreation and Swimming Pool | D. Toilet Compartment | D. Door has malfunctioning self-closing hinge G. Grab bars not provided H. Side grab bar < 42" long N. Non-compliant toilet paper dispenser T. Centerline < or > 18" (MAAB) | Swimming Pool - Women's Toilet Room | 1 | | Priority 3 | Additional Access | Repair hinge. Provide a rear grab bar that is 42" long min. and extends from the toilet 12" min. on one side and 24" min. on the other side (open side), provide a side wall grab bar that is 42" long min. located 12" max. from the rear wall. Relocate the flush control to the open side of the toilet (transfer side). Relocate toilet so the centerline is 18" from the side wall. | 1 | \$2,499 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | Project Management for the City of Montpelier | | | |
|-------------------------------------------------------------|----------------------------------------------------|-----------------------|-------------------------------------------------------------------------------------------------------------|------------------------------------------|------|-----|---------------|------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------------------|--------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 34 | Montpelier Elm Street Recreation and Swimming Pool | D. Toilet Compartment | D. Door has malfunctioning self-closing hinge H. Side grab bar < 42" long K. Rear grab bar < 42" long | Swimming Pool Men's Toilet Room | 1 | | Priority 3 | Additional Access | Repair hinge. Provide a side wall grab bar that is 42" long min. located 12" max. from the rear wall. Provide a rear wall grab bar that is 42" long min. and extends from the toilet 12" min. on one side and 24" min. on the other side (open side). | 1 | \$898 | | | |
| 35 | Montpelier Elm Street Recreation and Swimming Pool | D. Toilet Compartment | R. Coat hook > 48" | Swimming Pool Men's Toilet Room | 1 | | Priority 3 | Additional Access | Lower coat hook so that it is no higher than 48" above the finish floor. | 1 | \$75 | | | |
| 36 | Montpelier Elm Street Recreation and Swimming Pool | G. Shower Compartment | H. Control height < 38" or > 48" P. Seat is not between 17"- 19" high Q. Seat is not padded | Swimming Pool - Women's Changing Room | 1 | | Priority 3 | Additional Access | Mount seat between 17"- 19" above the finish floor. Provide a padded shower seat. | 1 | \$428 | | | |
| 37 | Montpelier Elm Street Recreation and Swimming Pool | G. Shower Compartment | Q. Seat is not padded | Swimming Pool Showers | 1 | | Priority 3 | Additional Access | Provide a padded shower seat. | 1 | \$300 | | | |
| 38 | Montpelier Elm Street Recreation and Swimming Pool | B. Play Areas | L. Surface not stable, firm, and slip-resistant | Playground Near Swimming Pool | Ext. | | Priority 3 | Additional Access | The playground area has an Engineered Wood Chip (EWC) surface that is in need of maintenance. Engineered Wood Chips are allowed but they must be inspected and maintained regularly to ensure continued compliance with the ASTM F standard. | 1 | \$0 | | | |
| 39 | Montpelier Elm Street Recreation and Swimming Pool | C. Field | A. Accessible spaces not provided at team seating Team seating not on an accessible route. | Softball Field Closest to Baseball Field | Ext. | | Priority 1 | Program Access | Provide a 36" x 48" clear floor space at team seating. Relocate team seating to an accessible route. (Cost for 3'x4' (12sq ft.) concrete - Typically 2.5'x4'.) | 2 | \$196 | | | |
| 40 | Montpelier Elm Street Recreation and Swimming Pool | C. Field | B. Accessible spaces not provided at sidelines seating | Little League Baseball Field | Ext. | | Priority 1 | Program Access | Provide a 36" x 48" clear floor space at sidelines seating. (Cost for a 36" by 48" concrete patch alongside bleachers and 10' stone dust route to it.) | 1 | \$205 | | | |
| 41 | Montpelier Elm Street Recreation and Swimming Pool | C. Field | B. Accessible spaces not provided at sidelines seating | Montpelier Recreation Field | 1 | | Priority 1 | Program Access | Provide space for a total of 11 wheelchair spaces (33" x 48" clear floor space) and 11 companion seats. (Cost is for 11 folding chairs to be used as companion seating. NOTE: It may be necessary to remove some portion of first row bleacher seating to yield necessary space.) | 11 | \$330 | | | |
| 42 | Montpelier Elm Street Recreation and Swimming Pool | C. Field | C. Field not connected to an accessible route | Little League Baseball Field | Ext. | | Priority 1 | Program Access | Ensure little league baseball field is connected to an accessible route. (Cost for 10' stone dust path.) | 1 | \$113 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | Project Management for the City of Montpelier | | | |
|-------------------------------------------------------------|----------------------------------------------------|-----------------------------|-------------------------------------------------------------|----------------------|------|-----|---------------|------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------------------|--------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 43 | Montpelier Elm Street Recreation and Swimming Pool | C. Field | D. Practice areas are not on an accessible route | Batting Cage | Ext. | | Priority 1 | Program Access | Provide an accessible route to practice areas. (Cost estimate for 10' asphalt path.) | 1 | \$130 | | | |
| 44 | Montpelier Elm Street Recreation and Swimming Pool | D. Court | C. Court is not connected to an accessible route | Basketball Court | Ext. | | Priority 1 | Program Access | Ensure basketball court is connected to an accessible route. (Cost for a 6' stone dust path.) | 1 | \$68 | | | |
| 1 | Green Mountain Cemetery | A. Exterior Access Route | J. Level changes > 1/4" | Maintenance Building | Ext. | | Priority 1 | Program Access | Alter change in level to be 1/4" high max. (Cost estimate for a 3' by 3' concrete patch.) | 1 | \$103 | | | |
| 2 | Green Mount Cemetery Offices | B. Interior Access Route | C. Surface openings > 1/2" E. Level changes > 1/4" | Chapel | 1 | | Priority 1 | Program Access | Replace or reposition so that openings are 1/2" max. and the long opening dimension is perpendicular to the dominant direction of travel. Alter change in level to be 1/4" high max. (Cost for a replacement grate.) | 1 | \$1,453 | | | |
| 3 | Green Mountain Cemetery | B. Interior Access Route | E. Level changes > 1/4" H. Accessible route not provided | Chapel | 1 | | Priority 1 | Program Access | Provide a ramp to speaking area 36" wide min. with a slope between 5% and 8.33% max. Include handrails 34" min. and 38" max. above ramp surface and edge protection on ramp. | 1 | \$1,028 | | | |
| 4 | Green Mount Cemetery Offices | C. Doors, Doorways, & Gates | L. Hardware not operable with a closed fist | Chapel Entrance | 1 | | Priority 1 | Program Access | Provide hardware that can be operable with one hand and not require tight grasping, pinching, or twisting of the wrist. | 1 | \$242 | | | |
| 5 | Green Mount Cemetery | K. Operable Parts | C. Reach < 15" or > 48"(forward/side approach) | Chapel Entrance | Ext. | | Priority 3 | Additional Access | Relocate information so that access is 48" max. above the ground. | 1 | \$128 | | | |
| 6 | Green Mountain Cemetery | K. Operable Parts | C. Reach < 15" or > 48"(forward/side approach) | Maintenance Building | Ext. | | Priority 3 | Additional Access | Relocate information so that access is 48" max. above the ground. | 1 | \$128 | | | |
| 7 | Green Mountain Cemetery | K. Operable Parts | H. Not operable with a closed fist | Near Entrance | Ext. | | Priority 1 | Program Access | Provide hardware that can be operable with one hand and not require tight grasping, pinching, or twisting of the wrist at water spouts located in multiple areas in cemetery. | 3 | \$1,479 | | | |
| 8 | Green Mount Cemetery Offices | S. Picnic Tables | C. At least 5% accessible spaces not provided | Maintenance Building | Ext. | | Priority 1 | Program Access | Ensure that at least 5% (minimum one) of dining surfaces are accessible. | 1 | \$700 | | | |
| 9 | Green Mountain Cemetery | H. Portable Toilet | B. Accessible portable toilets not provided | Maintenance Building | Ext. | | Priority 1 | Program Access | Ensure that at least 5% (minimum one) of portable toilets are accessible. | 1 | \$2,300 | | | |
| 10 | Green Mountain Cemetery | | Accessible route not provided. | Chapel Entrance | Ext. | | Priority 4 | Enhanced Usability | Best Practice: Due to limited space, consider providing an accessible route with a slope no greater than 5%. NOTE: The door on the opposite side was locked on the day of the survey. If the public enters though that door, provide a 5% max. slope accessible route there as well. | 2 | \$0 | | | |

| Information Provided by Institute for Human Centered Design | | | | | | | | | | | Project Management for the City of Montpelier | | | |
|-------------------------------------------------------------|---------------------------------------------|---------|-----------------------------------------------------|-----------------------|------|-----|---------------|------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------------------|--------------------|-------------------------|---------------------------------|
| ID | Facility Name | Element | Issue/Physical Barrier | Location | Fl. | Rm. | City Priority | Priority for Barrier Removal | Remedies | Quantity | Estimated Cost of Barrier Removal | Project Start Date | Project Completion Date | Responsible for Barrier Removal |
| 11 | Green Mount Cemetery Offices | | Clear floor space not provided at church pew bench. | Chapel | 1 | | Priority 4 | Enhanced Usability | Best Practice: Consider providing a church pew with clear floor space of 36" wide min. by 48" deep min. | 1 | \$0 | | | |
| 12 | Green Mountain Cemetery | | Drop-off area and parking not provided. | Main Driving Entrance | Ext. | | Priority 4 | Enhanced Usability | Best Practice: Consider providing a van-accessible parking space with access aisle and sign with the International Symbol of Accessibility and the words "Van Accessible" and/or a drop-off area on the closest accessible route to the chapel and entombment building entry. | 1 | \$0 | | | |
| 1 | July 3 Festival, Parade and Family Olympics | | Best practice. | Main Street | Ext. | | Priority 4 | Enhanced Usability | Recommend creating a drop-off area as close as possible to the Family Olympics and July 3 parade route so that people with mobility disabilities can more easily approach the various activities and attractions. | 1 | \$0 | | | |
| 2 | July 3 Festival, Parade and Family Olympics | | Best practice. | State House Walkway | Ext. | | Priority 4 | Enhanced Usability | Recommend moving some of the Family Olympics activities close to the Main Street sidewalk and walkway between Main Street and the State House so they are on a shorter accessible route. | 1 | \$0 | | | |